

Number	23-002167-PR01 (NW-A01-02-en-01)
Owner	PASCHOS AEBE Merkouriou 20 54655 Thessaloniki Greece
Product	Vertical sliding window
Designation	System: D3-Advance Shipping name: Retractable Window
Details	Manufacturer PASCHOS AEBE, - Thessaloniki; Material Aluminium; Type of opening Sliding; Overall dimensions (W x H) 4500 mm x 3000 mm
Special features	Test sequence. Material compatibility must be taken into account. Material durability must be taken into account. The strength, durability and material compatibility of the adhesive system was not part of the test and is tested separately.

Result **)

Air permeability according to EN 12207:2016-12



Class: 4

Resistance to wind load according to EN 12210:2016-03



Class: C1/B1

Watertightness according to EN 12208:1999-11



Class: 5A

**) Decision rule: For the evaluation of conformity, the measurement uncertainty was not taken into account.

ift Rosenheim
24.11.2023



Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing



Alexandros Simeonidis, B.Eng.
Operating Testing Officer
Building Component Testing

Basis *)

EN 14351-1:2006+A2:2016-09
*) and corresponding national versions
(e.g. DIN EN)

Test report: 23-002167-PR01 PB-A01-02-en-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: E51-A0493